



CITY OF CONCORD
New Hampshire's Main Street™
Community Development Department
Code Administration

David V. Hall
Code Administrator

BULLETIN #	TITLE	DATE ISSUED
2025-01	Generator Application Guide	August, 2025
SUPERSEDES	SOURCE	SUPERSEDES
2023-02	2023 NEC 300.5, NEC 445.18, NEC 700.7 A, 702.7 A	

Informational Bulletin 2025-01
Generator Application Guide

Additional generator Details

(Please upload this information when applying for an electrical permit for the generator.)

Purpose and Scope:

This bulletin clarifies the required additional generator details, code references, installation personnel, required inspections, and other permits for generator installations in the City of Concord, NH.

Additional Generator Details:

The standby generator power system will be: separately derived
 non-separately derived

The generator is rated to run: the entire building load
 selected circuits
 there will be load shedding

Please provide a diagram with the following information:

- Building footprints.
- Relevant property lines.
- Location of generator.
- Location of the service rated disconnecting means. (2023 NEC 445.18)
- Distances from generator to habitable buildings, openings, and ignition sources. (State Fire Marshal Informational Bulletin 2016-03 - Residential Stationary Generator Installation & Safety)

- Electrical trench routes and depths. (NEC 300.5)
- Locations of existing panels, new panels, and transfer switches.
- Utility meter location.
- Location of the sign at the service entrance equipment indicating type and location of generator. (NEC 700.7 A & 702.7 A)

Installation Personnel:

Only NH licensed electricians can perform electrical installations. All individuals must provide proof of a current NH Master, Journeyman, or Apprentice license at the time of the inspection.

Required Inspections:

- Electrical trench inspection.
- Final inspection.

Other Permits:

If the generator will run on fuel gas, please also submit the following form: Mechanical Permit Application Residential or Mechanical Permit Application Commercial. Only NH licensed Gas Fitters can perform gas installations. All individuals must provide proof of a current NH Master, Journeyman, or Apprentice license at the time of the inspection.

If the generator will run on diesel fuel, please contact Concord Fire at 225-8650 for other permits.